

**From:** [Hunt, Marshall](#)  
**To:** ["Bijit Kundu"](#)  
**Cc:** [Elliott, Ed](#)  
**Subject:** RE: AFUE DOE test method  
**Date:** Wednesday, July 01, 2015 10:34:06 AM

---

I want to keep them separate.

But I am open to your thoughts

I am inclined to ask that AFUE testing not be changed as a way of lower testing burden since the results are  $\pm 0.2$  AFUE. Also the new test does little more than update the test to ASHRAE. It does not address the fundamental problems with the metric.

Marshall B. Hunt  
Professional Mechanical Engineer  
Codes & Standards  
Pacific Gas & Electric Company  
415-260-7624  
[mbh9@pge.com](mailto:mbh9@pge.com)

---

**From:** Bijit Kundu [<mailto:BKundu@energy-solution.com>]  
**Sent:** Wednesday, July 01, 2015 11:38 AM  
**To:** Hunt, Marshall  
**Cc:** Elliott, Ed  
**Subject:** RE: AFUE DOE test method

Confirmed. **July 10**, the same day as the standards letter. As we have done in the past, we could consider folding comments for both the test procedure and the standards in one letter and submit to both dockets.

<http://www.regulations.gov/#!documentDetail;D=EERE-2012-BT-TP-0024-0026>

**Bijit Kundu** | (510) 482-4420 x261

---

**From:** Bijit Kundu  
**Sent:** Wednesday, July 01, 2015 7:47 AM  
**To:** [MBH9@pge.com](mailto:MBH9@pge.com); Ed Elliott  
**Subject:** Re: AFUE DOE test method

July 10. I'll confirm when I get to my desk.

Bijit Kundu  
Energy Solutions

----- Reply message -----

From: "Hunt, Marshall" <[MBH9@pge.com](mailto:MBH9@pge.com)>

To: "Bijit Kundu" <[BKundu@energy-solution.com](mailto:BKundu@energy-solution.com)>, "Ed Elliott" <[ESE1@pge.com](mailto:ESE1@pge.com)>

Subject: AFUE DOE test method

Date: Wed, Jul 1, 2015 7:24 AM

When are comments due

Sent from my iPhone

PG&E is committed to protecting our customers' privacy.

To learn more, please visit <http://www.pge.com/about/company/privacy/customer/>