



California Energy Commission

# Estimating Fuel Displacement for California Electricity Reductions

**Staff Workshop on Combined Heat and Power**  
Energy Commission, Hearing Room A

July 14, 2014

Bryan Neff

Electricity Analysis Office

Electricity Supply Analysis Division

[bneff@energy.ca.gov](mailto:bneff@energy.ca.gov)



# Outline

- Purpose
- Scope & Limits
- Characterizing Grid Resources
- Data Source & Assumptions
- Historic & Estimated Heat Rates
- Application & Examples
- Questions



# Purpose

- Estimate fuel displacement from avoided use of grid electricity
- Be an apples-to-apples way to compare programs
  - Be policy-neutral
  - Use a common set of assumptions
  - Displace similar resources
- Starting point for discussion



# Scope of Method

- Uses grid heat rates to calculate fuel displacement
- Two resource categories
  - Peaking
  - Load Following (off-peak)
- Uses annual average (not seasonal)
- Single state-wide projection




# Limits of Method

- Not a life-cycle analysis
- Not meant for short term evaluations
- Not a dispatch model
- Uses simplifying assumptions
- Only valid as long as assumptions hold



## Characterizing Grid Resources






# Data Assumptions

- QFER data
- Heat rates aggregated annually
- Single state-wide group
- System stability resources removed




## Decreasing Heat Rate Trends







# Heat Rate Projection Using Linear Regression





# Heat Rate Floor & Loss Factor


Technology	Mid	High	Low
Conventional CT	10,585	11,890	9,980
Advanced CT	9,880	10,200	9,600
Conventional CC	7,250	7,480	7,030
Conventional CC With Duct Firing	7,250	7,480	7,030

Source: See Energy Commission, CEC-200-2014-003-SD.

Avoided Line Loss =  $X / (1 - 0.078)$ , where  $X$  is the reduced grid demand




## Applicable Heat Rate Estimates





# Limited Peak Energy Displacement





# Using the Estimates

- General formula:  
(Peak Energy) x (Applicable Peak Heat Rate)  
+ (LF Energy) x (Applicable LF Heat Rate)  
= Displaced Electric Grid Fuel Equivalent
- Peaking resources limited to 2.5% energy annually
- CO<sub>2</sub> conversion factor of 117 lbs/MMBtu
  - Same as 0.05305 MT



# CHP Example

## Assumptions:

- 5 MW facility
- 80% capacity factor
- Down time during off-peak hours
- 43,800 MWh potential energy
  - 1,095 MWh on-peak (2.5% x annual potential)
  - 33,945 MWh off-peak (77.5% x annual potential)



## Combined Heat and Power (50/50)

Displaced fuel estimate for 2014:

$$\begin{aligned} & (547.5 \text{ MWh} \times 11,362 \text{ Btu/kWh}) \\ & + (16,972.5 \text{ MWh} \times 7,950 \text{ Btu/kWh}) + \\ & (547.5 \text{ MWh} \times 10,476 \text{ Btu/kWh}) \\ & + (16,972.5 \text{ MWh} \times 7,330 \text{ Btu/kWh}) \\ & = 271.3 \text{ billion Btus} \end{aligned}$$

Applying the CO<sub>2</sub> conversion factor yields:

$$\# \text{ BTUs} \times 117 \text{ lbsCO}_2 / \text{million Btus} = 31.7 \text{ million lbsCO}_2$$



# CHP Displaced Carbon Intensities

<b>Reduction Type</b>	<b>Total Avoided Grid Energy (MWh)</b>	<b>CO<sub>2</sub> Conversion (million lbsCO<sub>2</sub>)</b>	<b>Displaced Carbon Intensity (lbsCO<sub>2</sub>/MWh)</b>
All Onsite	35,040	33.0	942
All Export	35,040	30.4	868
50/50 mix	35,040	31.7	905
50/50 mix, sans peaking energy	35,040	31.3	893





# Conclusion

- Provides a common approach
- Program life-time estimates
- Standard for comparing relative value
  - Not a substitute for physical measurements
- Variation in displaced carbon intensities
  - Peak power and line losses
- Heat rates can be updated



# Appendix



# Historic Average Heat Rates

Year	Load Following Plants	Peaker Plants	Percentage of Load Balancing Energy from Peaking Resources
2001	9,653	12,017	8.5%
2002	8,865	11,154	6.1%
2003	8,140	11,100	3.7%
2004	7,742	11,186	3.1%
2005	7,681	11,099	2.4%
2006	7,599	10,756	1.7%
2007	7,487	10,808	1.7%
2008	7,545	10,578	2.1%
2009	7,447	10,771	2.1%
2010	7,371	10,802	1.8%
2011	7,540	10,755	2.9%
2012	7,448	10,899	2.8%
2013	7,365	10,271	3.7%



# Applicable Heat Rate Estimates

<b>Year</b>	<b>Load Following</b>	<b>LF: Onsite Equivalent</b>	<b>Peaking</b>	<b>Peaking: Onsite Equivalent</b>
<i>2014</i>	7,330	7,950	10,476	11,362
<i>2015</i>	7,295	7,912	10,419	11,300
<i>2016</i>	7,260	7,874	10,361	11,238
<i>2017</i>	7,225	7,836	10,304	11,176
<i>2018</i>	7,190	7,798	10,247	11,113
<i>2019</i>	7,155	7,760	10,189	11,051
<i>2020</i>	7,120	7,722	10,132	10,989
<i>2021</i>	7,085	7,684	10,074	10,927
<i>2022</i>	7,050	7,646	10,017	10,864
<i>2023 to 2030</i>	7,030	7,625	9,980	10,824

Source: Energy Commission, Electricity Analysis Office, Electricity Supply Analysis Division.



## Combined Heat and Power (onsite)

Displaced fuel estimate for 2014:

(1,095 MWh x 11,362 Btu/kWh)

+ (33,945 MWh x 7,950 BTU/kWh)

= 282.3 billion Btus

Applying the CO<sub>2</sub> conversion factor yields:

# Btus x 117 lbsCO<sub>2</sub> / million Btus = 33.0 million lbsCO<sub>2</sub>



## Combined Heat and Power (export)

Displaced fuel estimate for 2014:

(1,095 MWh x 10,476 Btu/kWh)

+ (33,945 MWh x 7,330 Btu/kWh)

= 260.3 billion Btus

Applying the CO<sub>2</sub> conversion factor yields:

# Btus x 117 lbsCO<sub>2</sub> / million Btus = 30.4 million lbsCO<sub>2</sub>



# Combined Heat and Power (50/50, sans peaking energy)

Displaced fuel estimate for 2014:

(17,520 MWh x 7,950 Btu/kWh)

+ (17,520 MWh x 7,330 Btu/kWh)

= 267.7 billion Btus

Applying the CO<sub>2</sub> conversion factor yields:

# BTUs x 117 lbsCO<sub>2</sub> / million Btus = 31.3 million lbsCO<sub>2</sub>